AD-764 709

DEVELOPMENT AND CONSTRUCTION OF A LINE-
TUNABLE FUNDAMENTAL-MODE PULSED HF/DF
LASER

Dietmar E. Rothe

Lumonics Research Limited

Prepared for:

Rome Air Development Center
Advanced Research Projects Agency

April 1973

RADC-TR-73-173
Final Technical Report
April 1973

DEVELOPMENT AND CONSTRUCTION OF A LINE-TUNABLE
FUNDAMENTAL-MODE PULSED HF/DF LASER

Lumonics Research Ltd.

The views and conclusions contained in this document are those
of the authors and should not be interpreted as necessarily
representing the official policies, either expressed or implied,
of the Defense Advanced Research Projects Agency or the U. S.
Government.

AUG 6 1973

Rome Air Development Center
Air Force Systems Command
Griffiss Air Force Base, New York

AD 764709

DEVELOPMENT AND CONSTRUCTION OF A LINE-TUNABLE
FUNDAMENTAL-MODE PULSED HF/DF LASER

Dietmar E. Rothe

Principal Investigator: Dietmar E. Rothe
                        Phone: 613 225-1606

Project Engineer: James W. Cusack
                        Phone: 315 330-3145

Approved for public release;
distribution unlimited.

DOCUMENT CONTROL DATA - R & D

(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)

1. ORIGINATING ACTIVITY (Corporate author)	2a. REPORT SECURITY CLASSIFICATION
Lumonics Research Ltd 1755 Woodward Drive Ottawa 5, Canada	Unclassified
	2b. N/A

3. REPORT TITLE

Development and Construction of a Line - Tunable Pulsed HF/DF Laser

4. DESCRIPTIVE NOTES (Type of report and inclusive dates)

Final Report   31 Oct 72 - 31 Apr 73

5. AUTHOR(S) (First name, middle initial, last name)

Dietmar E Rothe

6. REPORT DATE	7a. TOTAL NO. OF PAGES	7b. NO. OF REFS
April 73	~~72~~ 78	24

9a. CONTRACT OR GRANT NO.	9a. ORIGINATOR'S REPORT NUMBER(S)
F30602-72-C-0394	None
b. PROJECT NO.	
c.	9b. OTHER REPORT NO(S) (Any other numbers that may be assigned this report)
d.	RADC-TR-73-173

10. DISTRIBUTION STATEMENT

Approved for public release; distribution unlimited

11. SUPPLEMENTARY NOTES Monitored by	12. SPONSORING MILITARY ACTIVITY
James W. Cusack RADC/OCSE Griffiss AFB, NY 13440	Advanced Research Projects Agency 1400 Wilson Blvd. Arlington, VA 22209

13. ABSTRACT

This report describes a development program for the construction of a line-tunable single-mode pulsed TE-laser*, suitable for use with both HF and DF. Experiments performed with a prototype, aimed at suppression of the superradiant background, indicated that it was not possible to lower the optical gain significantly without adversely affecting the tuned pulse energies and the pulse-to-pulse energy reproducibility.

In the final laser configuration the superradiant background was removed with an in-line filter. The beam divergence was minimized by employing a fundamental-mode unstable resonator and a beam expander which produced a 10 cm diameter beam with a divergence of less than 0.2 milliradian in the far field.

The test program and the construction and performance of this laser system are discussed in detail herein.

    *TE refers to laser excitation in a pulsed transverse electric discharge.

DD FORM 1473
I NOV 65

1a

14 KEY WORDS	LINK A		LINK B		LINK C	
	ROLE	WT	ROLE	WT	ROLE	WT
Pulsed Chemical HF/DF Laser						
TE-Laser						
Spectral Tuning						
Unstable Resonator						
Single Fundamental Mode						
Superradiance						
Gain Suppression						
Pulse Shapes						
Tuned Spectral Output						
Intra-Cavity Grating						
Monochromator						
Beam Expander						

RADC-TR-73-173
Final Technical Report
April 1973

DEVELOPMENT AND CONSTRUCTION OF A LINE-TUNABLE
FUNDAMENTAL-MODE PULSED HF/DF LASER

Lumonics Research Ltd.

Rome Air Development Center
Air Force Systems Command
Griffiss Air Force Base, New York

PUBLICATION REVIEW

This technical report has been reviewed and is approved.

James W Cusack

RADC Project Engineer

iii

LIST OF CONTENTS

LIST OF FIGURES

V

ACKNOWLEDGEMENTS

I ABSTRACT

This report describes a development program for the
construction of a line-tunable single-mode pulsed TE-laser*,
suitable for use with both HF and DF. Experiments performed
with a prototype, aimed at suppression of the superradiant
background, indicated that it was not possible to lower the
optical gain significantly without adversely affecting the
tuned pulse energies and the pulse-to-pulse energy
reproducibility.

In the final laser configuration the superradiant background
was removed with an in-line filter. The beam divergence was
minimized by employing a fundamental-mode unstable resonator
and a beam expander which produced a 10 cm diameter beam
with a divergence of less than 0.2 milliradian in the far
field.

The test program and the construction and performance of
this laser system are discussed in detail herein.

*TE refers to laser excitation in a pulsed transverse
electric discharge.

II INTRODUCTION

a. History

The possibility of utilizing the energy release of an exothermic chemical reaction to produce a vibrational population inversion suitable for laser action was discussed by Polanyi[1] in 1961. The first such chemical hydrogen halide laser was subsequently demonstrated by Kasper and Pimentel[2] in 1965. In their work, amplified stimulated emission was obtained from vibrationally excited HCl molecules produced in a chemical reaction which was initiated by flash photolysis of a gas mixture containing hydrogen and chlorine. Chemically pumped laser transitions in HF were first reported in 1967 by Deutsch[3] in a pulsed longitudinal electric discharge. In the same year a pulsed HF laser was also described by Kompa and Pimentel[4].

Electric-discharge initiated chemical HF and DF lasers have since been studied and perfected by several investigators[5-20] employing various combinations of F donor molecules such as NF_3, CF_4, MoF_6, UF_6, $C Cl_2F_2$ etc. and hydrogen-containing compounds such as H_2, C_2H_6, C_3H_8, C_4H_{10}, HI, HBr, gasoline etc.

Relatively high electric energy-conversion efficiencies (1 to 5%), comparable with those of pulsed CO_2 lasers, have recently been obtained for HF lasers by employing transverse discharge techniques.[8-20] Highest pulse energies have been obtained when SF_6 was used in combination with H_2 or with ethane, propane or butane.

Temporal and spectral characteristics of the optical output pulse have been studied for transverse discharge lasers employing resistivily loaded pins by Jacobson and Kimbell[8, 9, 10], Green and Lin[11], Wood et al.[12, 13], Marcus and Carbone[14, 15], Deutsch[16] and Pummer and Kompa[17].

More recently, extended electrodes and double-discharge techniques were used at Lumonics[18] and by Wenzel and Arnold[19] and Jacobson and Kimbell[20] to improve further the effiency and pulse energy of such lasers.

b.   Program Goals

The research and development described herein was necessary for generating the decisions required for the design and construction of a pulsed HF/DF TE-laser system, which could meet simultaneously the following requirements:

1.   The laser was to be readily line tunable over all available HF and DF lines, with the spectral purity of the tuned output being better than 98 per cent.

2.   The average optical power on dominant spectral lines (at pulse repetition rates between one and ten pulses per second) was to be larger than 10 milliwatt.

3.   Pulse energy variation was to be less than $\pm$ 2 per cent.

4.   The laser was to operate in the fundamental transverse mode, and the beam divergence was to be approximately 0.1 mrad in the far field.

At the beginning of the development program these
specifications were beyond the state-of-the-art of HF
lasers, even though any one or two of these requirements
cou'd possibly have been met by an upgraded version
of a standard Lumonics HF/DF laser system.

The major stumbling block, which prevents the attainment
of high spectral purity and single-mode operation with
low beam divergence, is the extremely high gain of all
electrically initiated chemical HF lasers. In fact,
such lasers have been observed [5, 14, 15] to be superradiant
over an active length as short as one centimeter. Under
these conditions it is not possible to control the output
mode and spectral purity with the cavity reflectors.
A major part of the development effort consisted, therefore,
of a search for techniques which would reduce the optical
gain and suppress the superradiance without unduly
sacrificing pulse energy.

Characteristics of a typical pulse-initiated HF laser
are outlined in Section III. Details of the development
program are given in Section IV, and the resulting
laser design and performance are described in Sections
V and VI of this report.

III GENERAL CHARACTERISTICS OF PULSED HF/DF LASERS

Apart from its compact design, the transverse electrically
pulsed HF/DF laser has the advantage over other chemical
HF lasers insofar that easily available, non-corrosive
and non-toxic gases can be used as fuel. In addition, the
exhaust gases contain only relatively small amounts of HF
(or DF), simplifying the disposal problem. Best performance
characteristics have been obtained with

$$SF_6 + H_2 \text{ (or } D_2)$$
$$SF_6 + CH_4 \text{ (methane)}$$
$$SF_6 + C_2H_6 \text{ (ethane)}$$
$$SF_6 + C_3H_8 \text{ (propane)}$$
$$\text{or } SF_6 + C_4H_{10} \text{ (butane)} \quad \text{mixtures.}$$

In the operation of an electrically initiated HF laser,
the function of the glow discharge is to dissociate a
sufficient number of SF_6 molecules, i.e.

$$SF_6 + e \longrightarrow SF_5 + F + e. \tag{1}$$

The free fluorine atoms then react with the hydrocarbon
molecules to produce vibrationally excited HF atoms via the
reaction

$$F + C_nH_{2n+2} \longrightarrow HF^* + C_nH_{2n+1} . \tag{2}$$

where n = 0, 1, 2, 3, 4.

The energy release in this reaction which is available for vibrational excitation is 31.6 k cal/mole for H_2 or D_2 and is 32, 37, 40 and 43 k cal/mole for methane, ethane, propane and butane, respectively. The energies required to excite the first four vibrational states (above the ground state) of HF and DF are:

V	HF*	DF**
1	11.3 k. cal/mole	8.3 k cal/mole
2	22.2	16.3
3	32.5	24.0
4	42.4	31.5

* from Ref. 21   ** estimated from wavelengths
                           tabulated in Ref. 3

With ethane and propane the energy liberated is sufficient to populate the first three vibrationally excited states of HF. With butane the $v = 4$ state may also be excited; however, no $v = 4 \longrightarrow 3$ transitions have yet been observed. When hydrogen or methane are used in combination with SF_6, the $v = 3$ state of HF may only be excited if sufficient thermal energy is available from the gas discharge to supplement the chemical energy release. That this is indeed the case, is supported by the fact that strong laser action can be produced in the $v = 3 \longrightarrow 2$ transition band with hydrogen[10-13,18,20] or methane[20]. Similarly, one would expect lasing to occur on the $v = 4 \longrightarrow 3$ band of DF when SF_6 and D_2 are employed as fuel. However, P_4 lines have so far only been observed by Wood and Chang[13] and were not seen in the laser described herein.

The complimentary process of reaction (2) involving H atoms produced in the discharge (or by reaction 2 if H_2 is used) also takes place, i.e.

$$H + SF_6 \longrightarrow HF^* + SF_5 + 63 \text{ k cal/mole} \tag{3}$$

Even though the exothermicity of this reaction is higher than that of process (2), this reaction is too slow to contribute significantly to the gain buildup in the laser.

For efficient operation of the laser, the HF formed in the discharge should be removed between pulses and replaced by fresh gas. If this condition is not fulfilled, collisional de-activation of the vibrationally excited HF molecules and absorption of the radiation by ground-state HF molecules degrade the energy output of the laser.

The vibrational relaxation time of room-temperature HF is extremely short and has been measured [22] as $p\tau = 14$ ns - atm. As a consequence, the presence of only 1 to 2 torr of HF in the laser cavity completely quenches all laser action [15].

In addition to self-quenching processes, vibrationally excited HF may be de-activated by V-V and V-R exchange collisions between HF and H_2 or hydrocarbon molecules. The more complex molecules, containing many hydrogen bonds, appear to be more effective in this respect, so that the optimum percentage of hydrocarbon in the gas mixture is lower than for hydrogen.

The effects of de-activation of HF by hydrogen compounds is clearly seen in Fig. 1, which shows the optical pulse energy as a function of propane concentration for an early HF/DF laser prototype. The production efficiency of F atoms in the glow discharge, the chemical formation rate of HF molecules and the quenching rates are all pressure dependent. Optimum operating pressures for an SF_6 - hydrocarbon mixture are between 40 and 100 torr (Fig. 2). Best discharge voltages range from 10 to 25 kV/cm, respectively.

With the addition of helium, the operating pressure of the laser may be increased up to atmospheric pressure [10]. The pulse energy, however, is decreased somewhat at higher pressures (Fig.3).

Temporal gain measurements made by Marcus and Carbone [15] in a typical pulsed HF laser at approximately 30 torr show the small-signal gain reaching a maximum at $0.6 \mu s$ after pulse initiation and then decaying rapidly due to collisional de-excitation to half its peak value within 1.5 microsecond. As a consequence, the optical pulse usually lasts less than $1 \mu s$ (except at very low gas pressures, below 10 torr) [9, 20] and occurs within $0.5 \mu s$ of the leading edge of the current pulse. Accordingly, a current pulse which lasts longer than approximately $0.5 \mu s$ adds very little energy to the laser pulse. Maximum optical laser energy is, therefore, obtained with a short discharge pulse (small storage capacitor) of high energy content (high voltage). This behavior is confirmed in Fig. 4, which shows the output power and efficiency as a function of capacitor size for a prototype laser.

The early occurrence and short duration of the optical pulse also explains why bright arcs, which generally develop at the end of the current pulse, have little effect on the optical power output if the current pulse is longer than about 0.7 microsecond. As a result, the optical pulse-to-pulse amplitude stability of a hydrogen fluoride TE-laser is generally better than for a carbon dioxide TEA laser.

The performance curves in Figs. 1 to 5 were obtained with an early Lumonics prototype, which had an extremely slow gas exchange rate in the discharge tube (one change in 30 seconds) due to small pump size (50 l/min), restrictive pump lines and large discharge tube volume (15 cm diameter and 60 cm long). For convenience, the measurements were taken at a pulse frequency of 1 Hz, at which rate the HF accumulation in the optical cavity was already quite significant. As a consequence, the output energy per pulse and the electric efficiency were reduced to one third or less of their values at very low pulse repetition rates. In the gas flow range available, the optical output power varied linearly with volumetric gas exchange rate (Fig.5).

With more recent HF laser models, designed for more efficient gas exchange, optical pulses up to 500 mJ were obtained from a 50 cm long discharge (approximately 2 J/l) with efficiencies between 2.5 and 5% depending on pulse shape, electrode shape and applied voltage. Optical pulse energy was generally observed to increase linearly with increasing voltage up to approximately 15 to 20 kV per cm of discharge gap. At higher voltages, the pulse energy increased at a less than linear rate. Highest efficiencies are, therefore, obtained at lower voltages ($<$10 kV/cm).

Typical optical pulse shapes of an untuned HF laser are reproduced in Fig. 6. With SF_6 and H_2 the pulse width at the half-intensity points is 500 ns; with propane and other hydrocarbons it appears to be somewhat wider with a more slowly decaying trailing edge.

In general, only P-branch ($\Delta J = +1$) lines in the $v = 1 \rightarrow 0$, $v = 2 \rightarrow 1$ and $v = 3 \rightarrow 2$ vibration-rotation bands are observed in the output of a discharge-initiated HF/DF laser using SF_6 as the fluorine source. Even though most of these spectral lines are emitted superradiantly, it is possible to enhance any one of these by tuning the laser cavity with a diffraction grating. Spectral lines and wavelengths most often observed[13, 18, 20] for HF are:

$P_1(3) - P_1(9)$	2.608 - 2.823 μ
$P_2(2) - P_2(9)$	2.696 - 2.954 μ
$P_3(3) - P_3(7)$	2.854 - 3.005 μ

For DF the transitions most readily observed are:

$P_1(5) - P_1(11)$	3.581 - 3.789 μ
$P_2(3) - P_2(12)$	3.636 - 3.957 μ
$P_3(3) - P_3(12)$	3.756 - 4.090 μ

In lasers having insufficient gas flow, some or all of the P_1 lines may be absent, since these are readily absorbed by ground-state HF molecules. In addition, collisional quenching may also prevent some of the rotational transitions in the P_1, P_2 or P_3 bands from lasing.

IV   SPECTRAL TUNING EXPERIMENTS

The requirements of high output energies, excellent
tunability, single-mode operation and compact laser design
cannot be met simultaneously with a superradiant laser.
High pulse energies require a large discharge volume;
good spectral resolution and single-mode operation can
only be achieved with a long and narrow optical cavity.
For low optical gain and good tunability, on the other
hand, a short active laser length (a few cm) should be
used.   Reduction of the laser gain by other than geometrical
means was, therefore, highly desirable for the success of
this program.

It was evident from the start of the program that fulfillment
of all performance specifications could only be achieved by
one of two approaches.

Approach 1:   Reduction of the small-signal gain per unit length
              of the laser to a point where dominant lines are
              no longer superradiant.

Approach 2:   Removal of the unwanted superradiant spectral
              lines by means of a tunable filter.

There is no doubt that the first approach represents the more
elegant solution of the two. Consequently, the primary research
effort was channeled in this direction.

The least attractive way of reducing the gain of the active
medium would be to operate the laser under conditions for which
the collisional deactivation and optical absorption losses
are increased.

This could be done by increasing the partial pressures of the fuel gases, by reducing the gas flow, by increasing the H/F-ratio of the fuel or by priming the reaction with a long electrical pulse. With all these methods, a significant amount of HF would accumulate during the pulse or from pulse to pulse. The result would be a severe loss in the optical pulse energy and a reduction in the number of spectral lines which could be tuned in.

Decreasing the H/F-ratio (hydrogen-starved operation) or decreasing the total pressure would also result in lower pulse energies. In addition, the optical pulse would be lengthened[20], and the peak power decreased to an unacceptably low level.

High efficiencies, but low optical pulse energies, may be attained with low electrical power input (small storage capacitor). This approach was taken by Ultee[5], who achieved excellent spectral tunability, but obtained very low optical pulse energies (approximately 10 μ J per pulse per line).

The most direct way of reducing the laser gain is to decrease the stimulated emission cross-section. This may be accomplished by operating the laser at higher gas pressures, where the collision-broadening of the vibrational energy states significantly exceeds the Doppler broadening. Because the optimum H/F-ratio and partial pressures of the fuel gases are restricted to low values by the chemical reaction rates and de-activation rates, the pressure can only be increased by adding an inert gas. Helium is a logical choice here, since it is known to add stability to a glow discharge at high pressure.

Control over the frequency and the mode of the optical laser
beam can also be increased by employing an output reflector
of high reflectivity (i.e. low output coupling). This
establishes oscillation at the desired wavelength and in a
low-loss mode early during the excitation pulse, when the
gain has not yet built up to its maximum value. For the same
reason, an unstable output reflector gives better spectral and
mode control than an equivalent stable reflector (same output
coupling), because the very high reflectivity (close to 100%)
of the unstable reflector near the axis of the laser starts
controlled laser oscillation earlier during the temporal gain
build-up and, hence, at a lower gain per unit length. In
addition, a properly designed unstable resonator favors
single-mode oscillation, which in turn improves the spectral
resolution of the line-tuned system. For all these reasons,
the tuning experiments reported here were performed with an
unstable mirror configuration (see Sec. Vc).

The electrical driving circuit and discharge electrodes of
the experimental laser are shown schematically in Fig. 7.
The discharge electrodes were 50 cm long and 3.5 cm apart.
Approximately 11 J were stored in the 0.015 μf capacitor
and dumped across the discharge gap. A short pre-ionizing
pulse between a row of metal pins and the cathode preceded
the main pulse by approximately 0.5 μs (a more detailed
description of the discharge circuit is given in Sec. Va).

For the experimental data discussed in this section, the
unstable output reflector was designed for 5% output coupling
and an equivalent Fresnel number of one half. For intra-cavity
tuning, a 2.6 μ Jarrell-Ash plane reflection grating with
295 lines/mm and a 4.0μ Bausch and Lomb grating with 300 lines/mm
were used with HF and DF, respectively.

-13-

To study the effects of gas pressure on the tunability and the mode control, measurements were taken at two widely different conditions. At both conditions, the glow discharge was relatively stable, with arcs occurring only infrequently. The gas compositions and pressures were:

1. Low-Pressure Mode at 45 Torr:

$$SF_6 \quad - \quad 95\%$$
$$H_2(D_2) \quad - \quad 5\%$$
$$He \quad - \quad 0$$

2. High-Pressure Mode at 550 to 600 Torr:

$$SF_6 \quad - \quad 1.5\%$$
$$H_2(D_2) \quad - \quad 0.5\%$$
$$He \quad - \quad 98\%$$

HF spectra shown in Figs. 8 and 9 were recorded at the two pressure conditions by slowly scanning with the intra-cavity grating while pulsing the laser discharge at 2 pulses per second. The laser output was measured with a small thermopile (sensitive area 0.8 mm x 2 mm) placed near the inner edge of the annular laser beam. The signal from this detector was amplified and integrated and was then used to drive a millivolt chart-recorder operating at a slow chart speed. Scanning time for a complete spectrum was approximately 20 minutes. The apparent line widths were produced by "mode scanning" effects and by the long time constants of the integrator and recorder. The actual tuned power output of a specific line and of the untuned superradiant background were checked with a calibrated CRL thermopile power-meter for each recording.

Figure 8 illustrates the spectral line enhancement that can be obtained at an operating pressure of 45 torr by tuning the cavity. A maximum output of 125 mW was observed when the laser was tuned to the $P_1(7)$ line. A superradiant background of 20 mW was measured when the laser was detuned to a wavelength well outside of the vibrational HF-bands. At 550 torr (Fig. 9) maximum output was measured at 95 mW on the $P_2(5)$ line, and the background was found to be 8 milliwatt.

The spectral content of the untuned HF-laser output at low and high pressure is given in Figs. 10 and 11. These spectra were obtained by replacing the cavity grating with a flat reflector and analyzing the laser beam with an external monochromator (Czerny-Turner design made by McKee-Pedersen Instruments).

When deuterium was substituted for hydrogen, the tuned laser output (Fig. 12) at 45 torr showed a maximum average power of 70 mW on the $P_2(8)$ line and a low background of 8 milliwatt.

Close scruteny of the data displayed in Figs. 8 to 11 permits the following conclusions to be drawn:

1. The ratio of maximum tuned line intensity to superradiant background is 6.25 at 45 torr and 11.9 at 550 torr. This indicates that the "tunability" of the superradiant HF-laser is enhanced at high pressures; i.e. the gain has been lowered by pressure-broadening of the energy states, as predicted.

2.   The maximum tuned and untuned line intensities in each band
     occur at a lower rotational transition as the pressure is
     increased. This effect may be attributed to R-T energy
     exchanges between HF molecules and He atoms (rotational
     "cooling" of HF by helium).

3.   Although the tuned output spectrum contains approximately
     the same spectral lines as the untuned laser beam, the relative
     line enhancement achieved by cavity tuning is more pronounced
     for lines of low rotational quantum number (e.g. lines 4 to 6
     in the P_1 branch, lines 2 to 4 in the P_2 band and lines 2 and 3
     in the P_3 branch).

4.   The $P_1(5)$ line of HF and the $P_2(7)$ line of DF are inconsistently
     weak relative to their neighboring lines. The intensities of
     these lines can, however, be increased by filling the grating
     extension tube (1.5 m long) with helium. Evidently, these
     wavelengths are strongly absorbed by atmospheric H_2O and/or
     CO_2.

5.   For DF (Fig. 12), the ratio of maximum tuned line intensity
     to superradiance is 8.75 at 45 torr, somewhat higher than
     for HF. Hence, the optical gain with DF is naturally lower
     than with HF, making the DF laser more readily tunable.

The tuning experiments described above show that the optical gain
can be lowered significantly without loss of pulse energy by
going to higher gas pressures. As will be shown, however,
the pulse shape reproducibility as well as the pulse energy
stability of this laser are much poorer at high pressure than
at low pressure.

Each vertical line in Fig. 13 represents the integrated
optical pulse energy as obtained with a CRL power meter and
at a gas pressure of 45 torr. Over the several hundred pulses
recorded, the pulse energy variation is seen to be approximately
$\pm$ 3% at a pulse frequency of 1 Hz and approximately $\pm$ 8% at
2 pulses per second. The deterioration of pulse-energy stability
at higher pulse frequencies is caused by insufficient gas flow,
which in turn results in the formation of streamers and arcs in
the discharge.

The energy variation of the tuned laser output at 550 torr is
greater than $\pm$ 30% (Fig. 14), more or less independent of pulse
frequency, and is not believed to be the result of streamer or
arc formation. In fact, the observed pulse energy variations can
be correlated with corresponding pulse shape variations, the
cause of which has not been determined.

Optical pulse shapes were measured with a fast (rise time $<$ 20 ns)
room-temperature InSb photoconductive detector (Mullard RPY 78).
All optical pulses measured have a half-width of approximately
500 ns (Figs. 15-17) except for the P_1 lines, which have a
somewhat wider pulse ($\sim$700 ns). This suggests that the lasing
levels in the first vibrational state are partially populated by
cascading transitions from the higher vibrational levels. In
all cases, lasing starts between 30 to 100 ns after initiation of
the electrical pulse.

At 45 torr the optical pulses are smooth, single-peaked and have
an excellent shape reproducibility. Note that each oscilloscope
trace in Fig. 15 is made up of four consecutive pulses superimposed
on each other. The same is not true at the high-pressure
condition. Here, the pulse shapes exhibit a characteristic double-
peak (Fig. 16), which has also been observed by Jacobson and Kimbell[20].

Furthermore, the pulse shape varies widely from pulse to pulse (Fig. 17) for this operating condition.

As discussed earlier, the use of an unstable output reflector improves the tunability of the laser. It also makes it possible to separate the superradiant background from the tuned line output, because the two components are emitted with widely differing beam divergences. The tuned output is single-mode and has a very low beam divergence (< 0.5 m rad), whereas the superradiant emission has a divergence at least ten times larger. In the far field, the superradiance is, therefore, quickly lost, and the central single-mode beam is close to 99% spectrally pure. The latter has been shown to be true by focusing the laser beam with a long-focal-length mirror and by passing the beam through a small aperture (consistent with a 1 m rad beam divergence) at the focal point. Approximately half the tuned near-field energy was measured on the far side of the aperture, yet no measurable superradiant background could be detected when the laser was detuned.

V   DESCRIPTION OF LASER CONFIGURATION

Because of the unacceptably large variation in pulse energy and pulse shape at the high-pressure condition, the advantage of operating at a lower gain level could not be realized for the present system.   Instead, the laser system was designed for use in the lower-pressure regime, and the spectral impurity background was removed with an external filter.   The construction details and operating characteristics of the laser built for RADC are discussed in this section.

a)   Electrodes and Discharge Circuit

Several features have been employed in the design of this laser to keep the formation of bright arcs in the discharge to a minimum.   These are:

1.   A smooth electrode profile with carefully rounded edges to assure a uniform electric field in the interelectrode gap,

2.   A short current pulse (low circuit inductance) which stops the current flow before arc instabilities can develop,

3.   A method of pre-ionization, that produces a uniform degree of ionization throughout the discharge volume before the main current pulse flows.

A schematic of the laser discharge circuit and the location of pertinent components are shown in Figs. 7 and 18.   The internal structure of the laser discharge-tube consists of a perforated nickel cathode (K), a solid nickel anode (A) and a row of trigger pins serving as the pre-ionizer electrode.   The main electrodes are 5 cm wide, 50 cm long and are separated by 3.5 cm.

-19-

The electric   operating cycle consists of a slow charging
phase, during which the storage capacitor (0.015 μf) is
charged to 38 kV, and of a rapid discharge phase initiated by
a high voltage trigger pulse, which fires the primary spark
gap (SG1). A negative pulse, the energy of which is limited
by the pre-ionizing capacitor, forms a fast glow discharge between
the trigger pins and the cathode. This preliminary discharge
generates electrons in the main gap by photoionization via
ultraviolet light and soft X-rays and by electron penetration
through the perforated cathode. Meanwhile (within 0.5 to
2 μs), the auxiliary spark gap (SG2) has had time to break down
and conduct the main current pulse to the cathode and through
the gas in the inter-electrode region. The delay between
pre-ionizing pulse and main pulse is controlled by the pressure
in spark gap 2 and by the size of the cathode capacitor (500 pf).
Owing to the rapid electron attachment to SF_6 and fluorine radicals
(produced in the discharge), the pre-ionization is largely
ineffective at 45 torr (95% SF_6). At 550 torr (1.5% SF_6),
however, a definite improvement in discharge stability can be
attributed to the pre-ionization technique.

b.   Gas Flow and Controls

In order to prevent accumulation of HF in the discharge tube,
the gas has to be pumped through the laser at a rapid rate.
A 300 l/min mechanical pump is used in the present system to
maintain the gas flow and the discharge-tube pressure at a
constant level. Because of the relatively long 1 inch
diameter pump-line, the actual measured pumping speed at the
laser cavity is only 236 l/min (mostly SF_6). At this flow rate,
the gas in the discharge tube is displaced every 0.7 seconds.
Hence, the pulse energy remains constant with pulse repetition
frequency (PRF) up to approximately 2 Hz.

At higher PRF, the pulse energy starts to decrease, even though the average power still increases up to 5 Hz. For lower PRF, the gas throughput may be reduced by throttling the flow to the pump and simultaneously decreasing the gas input at the flow meters (Fig. 19).

The individual gases are introduced through separate flow meters, brought together in a mixing manifold and passed into the laser tube. To protect the output reflector and the Brewster window (Fig. 20) from the corrosive reaction products, fresh gas is introduced at both ends of the laser tube and pumped out at the center. For similar reasons, the vacuum gauge and vacuum switch are connected to the input side, rather than the exhaust side of the gas flow system. Separate flow meters and supply lines are provided for the nitrogen supply to the spark gaps, which operate between 5 and 25 psi above atmosphere.

The vacuum switch has been added as a safety feature. When the pressure in the discharge tube rises above a preset value between 50 and 760 torr, the gas flow is turned off, and the HV supply is deactivated. This protects the laser tube from being pressurized above the operating range and from any uncontrolled effects of air leaks.

Solenoid valves at the gas input (Fig. 19) are used to automatically start or shut off the gas flow to the laser. This permits the gas flow to be electrically interlocked with other controls and sensing devices. It also makes it possible to leave the flow meters set at a predetermined flow rate when turning off the laser, facilitating subsequent rapid start-up.

c.   Optical Design

The optical system (Figs. 20 and 21) of this laser includes
the basic laser cavity, an external spectral filter (grating
monochromator), a beam expander and two pulse energy monitors.
The monochromator has been added to eliminate the superradiant
background, which the high-gain laser emits in addition to the
tuned wavelength. The beam expander reduces the beam divergence
to a value which is suitable for atmoshperic transmission
measurements.

The laser cavity is formed by an unstable output reflector (U)
and a reflective diffraction grating (G1 in Fig. 20). A
sapphire Brewster window (B) separates the reactive gases from
the grating.

UNSTABLE OUTPUT REFLECTOR:

The unstable CaF_2 output reflector has two convex surfaces
and acts as a lens to collimate the output beam, which
would otherwise diverge at an angle determined by the
radius of curvature of the internal surface (45 m). A
circular area, 8.2 mm in diameter, in the center of the
inside surface of the lens has been gold-coated to reflect
75% of the incident wavefront back into the laser cavity. The
remaining 25% of the wave are allowed to escape around the
edge of the gold disc.

The curvatures and diameters of the front reflector surfaces
are carefully matched to the cavity length and flat rear
reflector (grating) to provide a high rejection ratio for all
higher order transverse modes and to permit oscillation on
the lowest order transverse mode only.

In the near field, the output beam consists of an annular ring defined by the diameter of the convex output mirror and the outer mode diameter. In the far field, the mode consists of a central circular beam of high intensity and a series of concentric diffraction rings. Approximately 1/4 to 1/3 of the near-field energy appears in the central spot in the far field. Proper choice of geometry insures that the principal maximum propagates with diffraction-limited divergence. For a more comprehensive treatment of unstable resonators, the reader is referred to the work by Siegman[23,24].

To understand the choice of cavity parameters, it is necessary to weigh carefully the following considerations:

1. For fundamental-mode operation of a TE laser, an unstable resonator makes use of a considerably larger volume of excited gas than a corresponding stable resonator. Hence the unstable cavity makes more efficient use of the available optical energy.

2. In view of the very high gain of a pulsed HF/DF laser, a relatively low optical output coupling < 25% is necessary in order to have maximum control over the mode quality and spectral purity of the output beam.

3. The fraction of the near-field energy which appears in the central maximum of the far-field beam increases with increasing output coupling.

4. The near-field energy is a function of the active length, the gain per unit length, the percent output coupling and the mode of the laser output.

In the present design approximately equal importance has
been attached to mode quality, reasonable control over
spectral output and maximum energy in the far field.

WAVELENGTH SELECTOR:

Wavelength tuning is achieved with an adjustable intra-
cavity diffraction grating, which forms the rear reflector
of the optical resonator. A motor-driven precision micrometer
(calibrated against wavelength) is used to greatly enhance
any specific spectral line in the HF or DF spectrum (Figs. 8,
9, 12). The design of the grating mount and motor drive is
illustrated in Figure 22.

The diffraction grating is a 300 line per mm "Bausch & Lomb"
replica, blazed for a nominal wavelength of 4 microns. It
has been found that this grating has a higher efficiency
(80 to 90%) for both the HF and DF wavelengths than other
available gratings blazed at lower wavelengths (2.6, 3.0,
3.5 microns).

SPECTRAL FILTER:

The external spectral filter (Figs. 20 and 21) is a modified
Czerny-Turner Monochromator, designed to eliminate all but
the spectral line for which the laser cavity is tuned. To
increase the transmission efficiency, the entrance slit
and the collimating mirror have been removed, and the laser
beam is passed directly onto the diffraction grating. The
grating is identical to that used in the laser cavity.

BEAM EXPANDER:

The basic beam expander (BE in Fig. 20) is a reflective
confocal Cassegrain system with an f-ratio of 1.8 and
an expansion ratio of 5. It is designed for a parallel
incident beam of 2.0 cm diameter and provides a collimated
output beam of 10 cm diameter. The degree of collimation can
be adjusted by changing the distance between the two reflectors.

Because the near-field mode of the unstable resonator is
ring-shaped, no beam energy is lost by the beam-obscuration
due to the small convex reflector. The four spider vanes,
however, cause some of the light energy to be diffracted
out of the beam. A CaF_2 lens (L3) of 38 cm focal length has
been added to the system (Fig. 20) to collimate the beam
coming from the spectrometer slit before going into the beam
expander.

BEAM DIVERGENCE:

The "far field" of a laser beam of diameter D may be defined
as any distance from the source larger than the distance
required for the peripheral rays of the laser beam to form
a diffraction maximum at the center of the beam. This
distance X_f may readily be shown to be

$$X_f = D^2/4\lambda \tag{4}$$

For a wavelength of 3 μ and a beam diameter of 2 cm, this
distance is 33 meter. For a 10 cm diameter beam, the far field
recedes to a distance of approximately 800 meter.

It is, therefore, impractical to test the beam divergence
by taking measurements in the far field directly. The far-field
pattern may be brought arbitrarily close, however, by focusing
the beam. This transforms the angular divergences into a
displacement pattern. In the focal plane, the distance, Y, of
an optical ray from the optical axis is related to its
angular deviation δ by

$$Y = \delta f \qquad (5)$$

where f is the focal length of the lens or mirror. The energy
distribution in the focal plane is a map of the angular
energy variation in the far field, independent of whether
the focusing element is placed into the near field or the
far field of the beam.

Typical near and far-field beam patterns of the laser cavity
itself are presented in Figure 23. The central maximum of the
far-field beam has an elliptical shape, because of azimuthal
non-uniformity in the near-field ring pattern. This uneven
intensity distribution was produced by a corresponding non-uniform
gain profile through the discharge gap.

The optical beam quality was improved after widening the
discharge by reshaping the electrodes (with a 40% loss in
optical pulse energy). Best far-field beam divergences were
measured to be 0.35 m rad x 0.2 m rad for the central spot
(Fig. 23).

A further reduction in beam divergence was accomplished by
increasing the beam diameter to 10 cm with the 5:1 beam
expander. Because of the large diameter, the near-field ring
shape of the beam is maintained for several hundred meters
(Fig. 24).

The far field was scanned with a 0.5 mm diameter aperture and a thermopile detector at the focus of a 25 m focal-length reflector. The half-width of the central peak was found to be 0.1 m rad x 0.2 m rad (Figs. 25 and 26). The non-symmetry of the "horizontal" profile is believed to be caused by the astigmatic and coma distortion due to the off-axis reflector in the monochromator. Because of the optical aberrations in the beam splitters, monochromator and beam expander, the reduction in beam divergence effected by widening the beam is only 1:2 instead of the theoretically possible value of 1:5.

VI PERFORMANCE SPECIFICATIONS OF DELIVERED SYSTEM

Input Power — 115 VAC, 60 Hz

Laser Head Dimension — 12"x20.8"x96"

Optical Platform — 3.5"x30"x96"
Structural Aluminum

Weight of Platform and Head — 400 Lb.

Electrical Control Console — 29"W x 24"D x 48"H
and H.V. Power Supply

Gas Control Console and — 29"W x 24"D x 48"H
Vacuum Pump

Remote Tuning Control — 10"W x 5"D x 3.5"H

Intra-Cavity Tuning — 300 Lines/mm Diffraction
Grating - manual and
motor drive

External Spectral Filter — Modified MP-1018-XM
McKee-Pedersen Spectrometer
with remote tuning and
read-out (0.5 m F.L.)

Beam Expander — 5:1 Cassegrain

Pulse Energy Monitors — Two "Sensors" Thermopiles

High Voltage Input — 0-50 KV (Variable)

Electrical PRF	- 0.5-20 Hz
Electrical Pulse Width	- 0.3 microsec (Half intensity points)
Gas Consumption	- SF_6: up to 14 l/min (12 Lb/hr) H_2 (or D_2): 0.1 l/min N_2 (Spark Gaps): 0.8 l/min He (optional): up to 120 l/min
Lasing Mixture	- 95% SF_6, 5% H_2 (or D_2) at 45 torr (Optional mixture: 98% He 1.5% SF_6, 0.5% H_2 or D_2 at 550 torr)
Optical Wavelengths	- 18 Lines between 2.6 and 3.1 microns for HF
	- 24 Lines between 3.5 and 4.1 microns for DF
Optical Pulse Energies	- 40 mJ on dominant HF line at laser output, 24 mJ after spectral filter, 17 mJ after beam expander, 8 mJ in far-field beam.
	- 30 mJ on dominant DF line at laser output, 20 mJ after spectral filter, 13 mJ after beam expander, 6 mJ in far-field beam.

Far-Field Peak Power — > 5 kW for at least 20 lines

Transmission Efficiencies — Spectral Filter: 60% at 2.8 μ

67% at 3.8 μ

— Beam Expander: 67%

Optical Pulse Width — 500 nsec (half-intensity points)

Spectral Purity of
Output Beam — > 99%

Beam Diameter — 10 cm

Modal Quality — Fundamental transverse mode
achieved with unstable
resonator optics

Far-Field Beam Divergence
of Central Maximum — < 0.2 m radian

Probability of Pulse
Occurrence — > 99%

Pulse Energy Variations — $\pm$ 3% at 1 Hz
$\pm$ 8% at 2 Hz
> $\pm$ 10% at PRF > 3 Hz

VII CONCLUSIONS AND SUGGESTIONS
FOR FUTURE DEVELOPMENT

It has been demonstrated that the gain of a pulsed chemical
HF/DF laser can be lowered significantly without loss of
optical energy when operated at high pressures. Improved
tuning and mode control was obtained under those conditions.
However, the pulse-to-pulse stability of energy and pulse
shape was poor. In order to make full use of this operating
regime, further studies are required to determine the cause
for the pulse shape variations at high pressures. It may
be possible to eliminate this problem by employing different
pre-ionization techniques.

A special unstable output reflector was designed and tested.
Additional control over the spectral output and the mode of
the laser beam was gained by the use of this reflector.

To improve the uniformity of the annular output beam and,
hence, the far-field divergence, future systems could be made
of several discharge sections rotated with respect to each
other. Furthermore, all auxiliary optics should be of extremely
accurate surface figure to avoid beam distortion.

Finally, a line-tunable laser system with intra-cavity
tuning and an external spectral filter and beam expander was
built and delivered to the U.S. Air Force. The system
performed satisfactorily and met most of the requirements set
out at the beginning of the program.

VIII REFERENCES

1. J.C. Polanyi, J. Chem. Phys. 34 (1961) 347;
    also Appl. Opt. Suppl. 2: Chem. Lasers 109 (1965).

2. J.V.V. Kasper and G.C. Pimentel, Phys. Rev. Letters 14
    (1965) 352.

3. T.F. Deutsch, "Molecular Laser action in hydrogen
    and deuterium halides", Appl. Phys. Letters 10
    (1967) 234.

4. K.L. Kompa and G.C. Pimentel, "Hydrofluoric acid
    chemical laser", J. Chem. Phys. 47 (1967) 857

5. C.J. Ultee, "Compact pulsed HF lasers", Rev. Scient.
    Instr. 42 (1971) 1174, also IEEE J. Quant. Electron.
    QE-6 (1970) 647.

6. M.C. Lin, "Chemical HF laser from NF_3-H_2 and $NF_3-C_2H_6$
    systems", J. Phys. Chem. 75 (1971) 284.

7. R.J. Jensen and W.W. Rice, "Electric discharge initiated
    SF_6-H_2 and SF_6-HBr chemical lasers", Chem. Phys.
    Letters 7 (1970) 627.

8. T.V. Jacobson and G.H. Kimbell, "Transversely spark-
    initiated chemical laser with high pulse energies",
    J. Appl. Phys. 41 (1970) 5210.

9. T.V. Jacobson and G.H. Kimbell, "Transversely pulse-
    initiated chemical lasers; Preliminary performance
    of the HF system", Chem. Phys. Letters 8 (1971) 309.

10. T.V. Jacobson and G.H. Kimbell, "Transversely pulse-initiated chemical lasers: Atmospheric-pressure operation of an HF laser", J. Appl. Phys. 42 (1971) 3402.

11. W.H. Green and M.C. Lin, "Pulsed-discharge initiated chemical lasers: III. Complete population inversion in HF", J. Chem. Phys. 54 (1971) 3222.

12. O.R. Wood, E.G. Burkhardt, M.A. Pollack and T.J. Bridges, "High-pressure laser action in 13 gases with transverse excitation" Appl. Phys. Letters 18 (1971) 261.

13. O.R. Wood and T.Y. Chang, "Transverse-discharge hydrogen halide lasers". Appl. Phys. Letters 20 (1972) 77.

14. S. Marcus and R.J. Carbone, "Performance of a transversely excited pulsed HF laser, "IEEE J. Quant. Electron. QE-7 (1971) 493.

15. S. Marcus and R.J. Carbone, "Gain and relaxation studies in transversely excited HF lasers, "IEEE J. Quant. Electron. QE-8 (1972) 651.

16. T.F. Deutsch, "Parameter studies of pulsed HF lasers," IEEE J. Quant. Electron. QE-7 (1971) 174.

17. H. Pummer and K.L. Kompa, "Investigation of a 1 J pulsed discharge-initiated HF laser", Appl. Phys. Letters 20 (1972) 356.

18. Lumonics HF/DF laser performance sheets (1971).

19. R.G. Wenzel and G.P. Arnold, "A double-discharge initiated HF laser" IEEE J. Quant. Electron QE-8 (1972) 26.

20. T.V. Jacobson and G.H. Kimbell, "Parametric studies of pulsed HF lasers using transverse excitation", IEEE J. Quant. Electron QE-9 (1973) 173.

21 R.J. Jensen and W.W. Rice, "Thermally initiated HF Chemical laser", Chem. Phys. Letters 8 (1971) 214.

22. J.R. Airey and S.F. Fried, "Vibrational relaxation of hydrogen fluoride", Chem. Phys. Letters 8 (1971) 23.

23 A.E. Siegman, "Stabilizing output with unstable resonators" Laser Focus (May 1971) 42.

24. A.E. Siegman and H.Y. Miller, "Unstable optical resonator-loss calculations using the Prony method" Appl. Optics 9 (1970) 2729.

FIGURE 1:

HF LASER POWER AS A FUNCTION OF PROPANE PERCENTAGE

(Total pressure and flow rate approximately constant)

SF_6 FLOW = 3 atm-l/min

He FLOW = 0

Total Pressure = 90 torr

(LUMONICS PROTOTYPE)

AVERAGE POWER (milliwatts @ 1 pps)

PROPANE FLOW RATE (atm-cc/min.)

20 PERCENT PROPANE

3.5

Figure 2:
HF LASER POWER AS A FUNCTION OF GAS PRESSURE AT CONSTANT FLOW
VELOCITY AND CONSTANT COMPOSITION   (LUMONICS PROTOTYPE)

SF_6 : C_3H_8 : He = 50 : 1 : 0 ; Volumetric Flow Rate = 19.5 l/min.

x

FIGURE 3:
THE EFFECT ON THE HF LASER POWER
OF THE ADDITION OF HELIUM TO THE
GAS MIXTURE

SF_6 FLOW $= 1.5$ ATM. $1/MIN.$

C_3H_8 FLOW $= 30$ ATM. $cc/MIN.$

SF_6 PRESSURE $= 30$ torr

C_3H_8 PRESSURE $= 0.6$ torr

(LUMONICS PROTOTYPE)

FIGURE 4: OUTPUT POWER AND EFFICIENCY AS FUNCTION OF CAPACITOR
SIZE (PULSE WIDTH) AT 35 KV (LUMONICS PROTOTYPE)
SF_6 FLOW = 3 atm - l/min
C_3H_8 FLOW = 0.06 atm - l/min
P = 86 TORR

38

FIGURE **5:**

HF LASER POWER AS A FUNCTION OF FLOW VELOCITY AT CONSTANT
PRESSURE AND COMPOSITION **(LUMONICS PROTOTYPE)**

Total Pressure = 85 torr; SF_6 : C_3H_8 : He = 50 : 1 : 0

FIGURE 6: HF-LASER OPTICAL PULSE SHAPES OBTAINED WITH
           PHOTON DRAG DETECTOR
           (PRESSURE = 50 TORR)

FIGURE 7:

LASER DISCHARGE CIRCUIT

FIGURE 8: HF LASER OUTPUT SCANNED WITH INTRA-CAVITY GRATING (P = 45 TORR)

P_1

P_2

P_3

SUPERRADIANT BACKGROUND

zero

4   2.640μ
5   2.673
6   2.707
3   2.727
    2.744
7
4   2.760
8   2.783
5   2.795
9   2.823
6   2.832
3   2.854
    2.871
4   2.889
8   2.911
5   2.926
9   2.954
6   2.964
7   3.005μ

FIGURE 9: HF LASER OUTPUT SCANNED WITH INTRA-CAVITY GRATING (P = 550 TORR)

43

FIGURE 10: HF — SPECTRUM OF UNTUNED LASER EMISSION SCANNED WITH EXTERNAL SPECTROMETER
(P = 45 TORR)

FIGURE 11: HF - SPECTRUM OF UNTUNED LASER EMISSION SCANNED WITH EXTERNAL SPECTROMETER

(P = 580 TORR)

FIGURE 12: DF LASER OUTPUT SCANNED WITH INTRA-CAVITY GRATING (P = 45 TORR)

Pulse Energy Variation of Laser Output Tuned to
HF - $P_1(7)$ Line (p = 45 torr)

at 1 Hz

at 2 Hz

FIGURE 13   47

Energy Variation of Tuned Laser Output at 550 torr
(with HF)

$P_1(7)$ at 1 Hz

$P_2(6)$ at 1 Hz

$P_2(6)$ at 2 Hz

FIGURE 14   48

$P_1(7)$

500 ns per cm

Start of electrical discharge

$P_2(6)$

500 ns per cm

← 500 ns

$P_3(6)$

500 ns per cm

FIGURE 15:

OPTICAL PULSE SHAPES OF HF-LASER (4 pulses superimposed)

Pressure: 45 Torr, 6% H_2 , 94% SF_6

Detector: Mullard RPY 78 InSb Photoconductive Film

49

P₁(7)

500 ns per cm

Start of electrical discharge

P₂(6)

500 ns per cm

500 ns

P₃(6)

500 ns per cm

FIGURE 16:

OPTICAL PULSE SHAPES OF HF-LASER (single pulse)

Pressure: 550 Torr, 98% He, 1.5% SF_6, 0.5% H_2

Detector: Mullard RPY 78 InSb Photoconductive Film

50

Start of electrical discharge

500 ns

FIGURE 17:

PULSE-TO-PULSE VARIATION OF $P_1(7)$ LINE (HF) AT 550 TORR

98% He, 1.5% SF_6, 0.5% H_2

Detector: Mullard ROY 78 InSb Photoconductive Film

51

FIGURE 18: LASER DISCHARGE SECTION

FIGURE 19: GAS FLOW SYSTEM

LASER BEAM OPTICS

EXTERNAL SPECTRAL FILTER

FIGURE 20

A = Micrometer drive for intra-cavity grating

B = Sapphire Brewster window

BE = Cassegrain beam expander (1:5) f/1.8

C = Differential micrometer adjustments for output reflector

D1 = Pulse energy monitor (Sensors L66-3M thermopile)

D2 = Pulse energy monitor (modified Sensors C1 thermopile)

G1 = 300 l/mm intra-cavity grating

G2 = 300 l/mm spectrometer grating

L1, L2 = Uncoated germanium lenses

L3 = Uncoated CaF$_2$ lens (f.l. = 38 cm)

M = Spherical focusing mirror (f.l. = 45 cm)

P = Plane reflector

R = Sapphire flat, coated for 95% reflectance at 45°

S = CaF$_2$ beam splitter (90% transmission)

U = Gold-coated CaF$_2$ unstable output reflector (25% output coupling)

5-4

ELECTRICAL CONTROLS

GAS CONTROLS

REMOTE TUNING

LASER HEAD

BEAM EXPANDER

MONOCHROMATOR

FIGURE 21: HF/DF LASER SYSTEM

DIFFRACTION GRATING

AXIS OF ROTATION

MICROMETER DRIVE

MOTOR

FIGURE 22: GRATING MOUNT AND DRIVE

56

NEAR-FIELD PATTERN
(full scale)
WITH NARROW ELECTRODES

FAR-FIELD PATTERN

NEAR-FIELD PATTERN
(full scale)
WITH FLATTENED ELECTRODES

FAR-FIELD PATTERN

FIGURE 23: CROSS-SECTIONS OF THE OUTPUT BEAM FROM THE UNSTABLE CAVITY
FOR TWO DIFFERENT ELECTRODE SHAPES

57

10 cm

Near-Field Beam Profile 50m from Laser

FIGURE 24

58

Energy Distribution in the central Spot of Far-Field Beam (fast recording circuit)

FIGURE 25   59

Energy Distribution in the Central Spot of Far-Field Beam (integrating circuit)

FIGURE 26

60

X   APPENDIX

SYSTEM SAFETY ANALYSIS

The types of safety hazards encountered during the operation
of this laser system (Lumonics HF/DF Laser) may be classified
under three headings:

> A.   Electric,
>
> B.   Optical,   and
>
> C.   Chemical.

Each of these will be discussed separately and in detail below.

Safety aspects have been given due consideration during all design
phases of this system, and wherever possible, special safety
devices have been incorporated to minimize such hazards. All known
hazards have been identified in the instruction manual, and procedures
have been written in such a way as to avoid hazardous situations.
Hazard levels encountered may be classified as "marginal"
(Category II), and could only become "critical" (Category III
through negligence on the part of the operating personnel.

A.   ELECTRIC   HAZARDS

Molecular excitation of the gas mixture in a pulsed
TE-laser is either produced or controlled (as in the
present case) by the application of high voltage pulses
(up to 40 kV in the system described). All high-voltage
(HV) components have been completely enclosed in
electrically grounded metal cabinets equippped with
safety interlock switches. HV areas and components have
been identified by "High-Voltage Warning" signs.

Major HV components are:

1. HV Power Supply in Electric Control Cabinet,

2. HV Storage and Discharge Circuit inside Laser, Cabinet

3. HV Trigger Module in Laser Cabinet.

4. HV Cable between Control Cabinet and Laser Cabinet is properly shielded and grounded.

The safety interlocks prevent the generation and application of high voltages to any of the system components, if either the laser cabinet cover or the control cabinet door are not closed.

If it is necessary during maintenance procedures to open the electric control console or the laser cabinet, all AC power to the system should first be switched off and the control console be unplugged. Before attempting to perform any work inside the laser cabinet, the terminals of the storage capacitor should first be shorted to ground, as the capacitor is able to store a lethal charge, should some of the electrical connections become loose or "open circuited".

B.   OPTICAL HAZARDS

The HF/DF-laser system produces microsecond pulses of radiation in the wavelength range between 2.7 and 4.1 micrometers. Maximum pulse energy of the tuned laser system is less than 100 mJ.

Radiation in this wavelength range is generally absorbed by liquid water, but is partially transmitted by various glasses and plastics.

POSSIBLE EYE DAMAGE:

Retinal damage of the eye cannot occur at these wavelengths, since practically all the energy is absorbed in the cornea. Eye damage would, therefore, be restricted to superficial corneal burns and/or damage resulting from the heating effect due to absorption of the energy within the anterior chamber of the eye. The energy density in the unfocused beam from the laser described herein is too small to cause surface burns, and the amount of energy that can enter the eye is not sufficient to cause any noticeable heating effects. The focused beam, however, has been shown to produce burns on skin tissue.

Whenever there exists the possibility that operating personnel may encounter focused beam reflections from this laser, suitable safety goggles should be worn.

Transmittances measured through various glasses, plastics and goggles placed into the laser beam ($\lambda = 2.79$ μ) are:

2 mm thick plexiglass	- 5%
6 mm thick "Lexan" polycarbonate	- $<$0.1%
Prescription eye glasses	- 40-80%
"Sellstrom" (SM) safety glasses	- 35%
"Laser-Gard" gallium-arsenide neodymium goggles	- 1.5%
"Eastern Safety E28-5" propionate plastic goggles	- 0.2%

Transmittances measured in the untuned multiline HF laser beam (2.6 - 3.1 μ) are:

Prescription eye glasses	-	40-70%
1/4 mm liquid water	-	10%
"Eastern Safety E28-5" propionate plastic goggles	-	0.2%

Transmittances measured at a DF wavelength (3.80 μ) are:

Prescription eye glasses	-	30-35%
"Eastern Safety E28-5" propionate plastic goggles	-	$< 0.1\%$

Of the glasses tested, the propionate plastic goggles appear to give the best protection. Note that ordinary eye glasses afford inadequate eye protection against either HF or DF radiation.

C.   CHEMICAL HAZARDS

The hazards involved in handling fuel gases and exhaust gases are of a different nature and are discussed in turn.

FUEL GASES:

The fuel gases recommended for this laser are both non-corrosive and non-toxic (H_2, SF_6, He, D_2), and no material problems exist with respect to the gas feeding system. The gases are introduced at both ends of the laser cavity to protect the end flanges and optical reflectors from coming in contact with any corrosive reaction products. Similarly, the vacuum gauge and vacuum switch are connected to the gas inlet system.

Sulphur-hexafluoride is considered chemically and
physiologically inert, and becomes dangerous only
when heated to decomposition.

Hydrogen and deuterium is a colorless gas, which burns
with a colorless flame when heated above the ignition
temperature in air or oxygen. Spontaneous combustion
may occur in the presence of certain catalysts (such as
powdered platinum).

Precautions necessary for handling hydrogen are those
generally applied to the storage and handling of
highly flammable gases. Storage sheds should be well
ventilated and should be equipped with hydrogen detectors
and alarms.

The amount of hydrogen used in the present system is
very small (less than one liter per minute), and the
concentration of hydrogen in the lasing mixture is low
(less than 5%). Only a small amount of compressed
hydrogen needs to be stored near the laser (50 ft^3 or
less) to minimize the fire hazard.

Furthermore, the amount of hydrogen, which can react with
fluorine in the laser cavity is controlled by the number
of free fluorine atoms produced in the electrical
discharge. Uncontrolled chemical chain reactions (as
with $H_2 + F_2$) are not possible with the suggested gas
mixture. The quantity of hydrogen which reacts per pulse
is again only 5% of the amount introduced, and the heat
liberated is negligible.

65

Although the laser has been thoroughly leak-checked and
is not likely to develop leaks under normal operation,
frequent leak checks should be performed to prevent
uncontrolled amounts of air entering the gas system.

The explosion hazard due to uncontrolled leaks is minimal
due to:

1.   The low partial pressure of hydrogen in the
        laser (2 torr),
2.   The inhibitive action of the SF_6 diluent,
3.   The action of the safety vacuum switch, which will
        shut off the gas flow and the HF supply, should the
        pressure in the discharge tube rise above a
        preset limit.

EXHAUST GASES

Both corrosive and toxic gases are produced in the
discharge tube and are pumped out through the vacuum
pump. The pump exhaust must therefore be vented outside
the laboratory. The exhaust stack should be located well
away from populated buildings. In areas where strict
pollution standards do not permit dispersion of toxic
gases in the atmosphere, the pump exhaust must be
chemically scrubbed to remove HF and sulphur compounds
before venting into the atmosphere. Hydrogen fluoride
may be removed by passing the exhaust through a solid
pebble trap of soda-lime or by bubbling the exhaust
through a tall column of alkaline solution (e.g. NaOH).

Specific compounds found in the exhaust are:

Undissociated SF_6	$>$ 80% at low pressure operating condition
He	$>$ 90% at high pressure operating condition
HF	$<$ 1%
H_2S	negligible
Decomposition products of SF_6 (SF_n, where n = 1, 2, 3, 4, 5)	$<$ 5%
S_2 (as finely divided powder)	Deposited in discharge tube and pump lines.

The actual quantity of HF produced is 5×10^{-5} g-mole/pulse (or 1 milligram/pulse). This number is consistent with the calculated amount based on gas-kinetic and energy considerations, and agrees also with the measured amount in the exhaust obtained by titrating a NaOH solution. Note that almost all the HF passes through the pump and is not trapped in the oil.

A mass spectrometer analysis of the laser exhaust was performed by the Canadian Defence Research Establishment at Valcartier (DREV) and compared with a similar analysis of SF_6, in order to determine the relative concentrations of SF_5, SF_4 etc. in the exhaust. No noticeable difference was found, indicating that the concentrations of the decomposition products of SF_6 are small.

The toxicities of the SF_n products are largely unknown and must all be considered as highly toxic.

Cleaning of the discharge tube and changing the pump oil should only be done in well ventilated areas, and direct skin contact with contaminated surfaces should be avoided by wearing disposable plastic gloves.